

04/05/2015

Mr. Adrian Donnelly,  
 Treasurer Killone GWS,  
 Imleach,  
 Barntick,  
 Ballynacally,  
 Co. Clare.

Report No. 7654  
 Ref: 26-50

Dear Adrian,

**Re: Drinking Water Quality Certification – April 2015**

We examined six drinking water samples taken from the indicated locations on the 29/04/2015 to determine the level of compliance with the drinking water/food regulations on coliforms and chemical parameters indicated.

**Regulations:** SI 278 of 2007 and the Drinking Water Directive.  
 Food hygiene regulations

Sample location	Sample No.	Total coliforms No./100 mL	E. Coli No./100 mL	Residual free chlorine mg/L	Total chlorine mg/L
Pat Haren	19151	<1	<1	0.85	0.85
Andy Price	19152	<1	<1	0.75	0.75
Creche	19153	<1	<1	0.91	0.91
Michael Hogan	19154	<1	<1	0.85	0.85
School/Hall	19155	<1	<1	0.54	0.54
Sheedy's Shop	19156	<1	<1	0.54	0.54

**Drinking Water Quality Rating:** Please maintain free chlorine levels at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Sincerely,

Signed: 

Lorna Moynihan

Amberley Water Solutions Ltd.