

Drinking Water Quality Certification – April 2023

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10775
Reference: 39-139
Date Sampled: 20 Apr 2023
Date Reported: 23 Apr 2023

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	30962	<1	<1	0.18	0.18
R Murphy	30963	<1	<1	0.38	0.38
Michael Hogan	30964	<1	<1	0.42	0.43
School	30965	<1	<1	0.18	0.18
Londis Shop	30966	<1	<1	0.24	0.24
Banner Steel	30967	<1	<1	0.10	0.10

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.