

Drinking Water Quality Certification –Apr 2024

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 11272
Reference: 41-66
Date Sampled: 28 Mar 2024
Date Reported: 07 Apr 2024

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	33134	<1	<1	0.16	0.16
R Murphy	33135	<1	<1	0.47	0.47
Michael Hogan	33136	<1	<1	0.36	0.36
School	33137	<1	<1	0.08	0.08
Londis Shop	33138	<1	<1	0.08	0.08
Banner Steel	33139	<1	<1	0.04	0.04

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.