

## **Drinking Water Quality Certification – August 2019**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 9157  
**Reference:** 33-75  
**Date Sampled:** 09 Aug 2019  
**Date Reported:** 24 Aug 2019

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	25091	<1	<1	0.13	0.16
R Murphy	25092	<1	<1	0.18	0.21
Creche	25093	<1	<1	0.11	0.13
Michael Hogan	25094	<1	<1	0.16	0.23
School/Hall	25095	-	-	-	-
Sheedy's Shop	25096	<1	<1	0.13	0.15

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

The School was closed at the time of sampling.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.