

## **Drinking Water Quality Certification – August 2021**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 9931  
**Reference:** 36-89  
**Date Sampled:** 06 Aug 2021  
**Date Reported:** 13 Aug 2021

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	27844	<1	<1	0.13	0.16
R Murphy	27845	<1	<1	0.34	0.36
Creche	-	-	-	-	-
Michael Hogan	27846	<1	<1	0.18	0.24
School/Hall	-	-	-	-	-
Londis Shop	27848	<1	<1	0.06	0.09

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.