

Drinking Water Quality Certification – August 2022

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10428
Reference: 38-63
Date Sampled: 02 Aug 2022
Date Reported: 12 Aug 2022

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	29536	<1	<1	0.11	0.12
R Murphy	29537	<1	<1	0.34	0.36
Michael Hogan	29538	<1	<1	0.36	0.37
School	29539	<1	<1	0.05	0.06
Londis Shop	29540	<1	<1	0.11	0.11
Banner Steel	29541	<1	<1	0.06	0.07

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.