

Drinking Water Quality Certification – August 2023

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10942
Reference: 40-43
Date Sampled: 10 Aug 2023
Date Reported: 14 Aug 2023

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	31660	<1	<1	0.11	0.11
R Murphy	31661	<1	<1	0.30	0.30
Michael Hogan	31662	<1	<1	0.20	0.20
School	-	-	-	-	-
Londis Shop	31664	<1	<1	0.10	0.10
Banner Steel	31665	<1	<1	0.16	0.16

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

School closed for Summer Holidays.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.