

### **Drinking Water Quality Certification – August 2024**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 11447  
**Reference:** 41-184  
**Date Sampled:** 12 Aug 2024  
**Date Reported:** 15 Aug 2024

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

| Sample Location | Sample No. | Total Coliforms No./100 mL | <i>E. coli</i> No./100 mL | Free Chlorine mg/L | Total Chlorine mg/L |
|-----------------|------------|----------------------------|---------------------------|--------------------|---------------------|
| Pat Haren       | 34024      | <1                         | <1                        | 0.14               | 0.14                |
| R Murphy        | 34025      | <1                         | <1                        | 0.36               | 0.36                |
| Michael Hogan   | 34026      | <1                         | <1                        | 0.37               | 0.37                |
| School          | -          | -                          | -                         | -                  | -                   |
| Londis Shop     | 34028      | <1                         | <1                        | 0.18               | 0.18                |
| Banner Steel    | 34029      | <1                         | <1                        | 0.06               | 0.06                |

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

School closed for holidays.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.