

Drinking Water Quality Certification – December 2021

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10088
Reference: 37-19
Date Sampled: 20 Dec 2021
Date Reported: 22 Dec 2021

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	28341	<1	<1	0.19	0.24
R Murphy	28342	<1	<1	0.33	0.35
Creche	-	-	-	-	-
Michael Hogan	28344	<1	<1	0.65	0.70
School/Hall	28345	<1	<1	0.07	0.09
Londis Shop	28246	<1	<1	0.14	0.15

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

The Creche was closed at the time of sampling.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.