

Drinking Water Quality Certification – December 2023

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 11110
Reference: 40-148
Date Sampled: 01 Dec 2023
Date Reported: 10 Dec 2023

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	32287	<1	<1	0.01	0.01
R Murphy	32288	<1	<1	0.46	0.48
Michael Hogan	32289	<1	<1	0.05	0.05
School	32290	<1	<1	0.00	0.10
Londis Shop	32291	<1	<1	0.04	0.04
Banner Steel	32292	<1	<1	0.00	0.00

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.