

### **Drinking Water Quality Certification – December 2024**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 11607  
**Reference:** 42-96  
**Date Sampled:** 04 Dec 2024  
**Date Reported:** 07 Dec 2024

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	34707	<1	<1	0.86	0.86
R Murphy	34708	<1	<1	0.98	0.98
Michael Hogan	34709	<1	<1	0.85	0.85
School	34710	<1	<1	0.77	0.77
Londis Shop	34711	<1	<1	0.68	0.68
Banner Steel	34712	<1	<1	0.70	0.71

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.