

Drinking Water Quality Certification – February 2021

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9687
Reference: 35-102
Date Sampled: 16 Feb 2021
Date Reported: 21 Feb 2021

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	-	-	-	-	-
R Murphy	27023	<1	<1	0.33	0.44
Creche	27024	<1	<1	0.07	0.13
Michael Hogan	27025	<1	<1	0.39	0.47
School/Hall	-	-	-	-	-
Londis Shop	27027	<1	<1	0.08	0.16

Comment: No Coliforms or *E. coli* were detected in the samples tested. Please ensure to maintain free chlorine at approx. 0.2 mg/L.

Samples were not taken from locations: P. Haren or the School due to Covid-19 Restrictions.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.