

### **Drinking Water Quality Certification – February 2024**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 11203  
**Reference:** 41-15  
**Date Sampled:** 07 Feb 2024  
**Date Reported:** 10 Feb 2024

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	32781	<1	<1	0.12	0.12
R Murphy	32782	<1	<1	0.33	0.34
Michael Hogan	32783	<1	<1	0.34	0.34
School	32784	<1	<1	0.08	0.08
Londis Shop	32785	<1	<1	0.12	0.12
Banner Steel	32786	<1	<1	0.05	0.05

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.