

### **Drinking Water Quality Certification – February 2025**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 11694  
**Reference:** 42-143  
**Date Sampled:** 11 Feb 2025  
**Date Reported:** 17 Feb 2025

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	35037	<1	<1	0.07	0.10
R Murphy	-	-	-	-	-
Michael Hogan	35039	<1	<1	0.06	0.08
School*	-	-	-	-	-
Londis Shop	35041	<1	<1	0.10	0.10
Banner Steel	35042	<1	<1	0.11	0.12

\*School was closed.

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

The School was closed and there was no flow at Murphy's, so we were unable to sample.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.