

Drinking Water Quality Certification – January 2022

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10137
Reference: 37-31
Date Sampled: 07 Jan 2022
Date Reported: 09 Jan 2022

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	28412	<1	<1	0.25	0.28
R Murphy	28413	<1	<1	0.51	0.54
Creche	-	-	-	-	-
Michael Hogan	28415	<1	<1	0.64	0.68
School/Hall	28416	<1	<1	0.10	0.10
Londis Shop	28417	<1	<1	0.06	0.06

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

The Creche was closed at the time of sampling.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.