

### **Drinking Water Quality Certification – January 2025**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 116565  
**Reference:** 42-117  
**Date Sampled:** 09 Jan 2025  
**Date Reported:** 12 Jan 2025

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	34868	<1	<1	0.69	0.69
R Murphy	-	-	-	-	-
Michael Hogan	34870	<1	<1	0.92	0.92
<i>School*</i>	-	-	-	-	-
Londis Shop	34872	<1	<1	0.22	0.22
Banner Steel	-	-	-	-	-

\*School was closed.

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

Two taps frozen unable to sample.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.