

23/07/2015

Mr. Adrian Donnelly,
Treasurer Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No. 7737
Ref: 26-89

Dear Adrian,

Re: Drinking Water Quality Certification – July 2015

We examined six drinking water samples taken from the indicated locations on the 10/07/2015 to determine the level of compliance with the drinking water/food regulations on coliforms and chemical parameters indicated.

Regulations:


SI 278 of 2007 and the Drinking Water Directive.
Food hygiene regulations

Sample location	Sample No.	Total coliforms No./100 mL	E. Coli No./100 mL	Residual free chlorine mg/L	Total chlorine mg/L
Pat Haren	19320	<1	<1	0.20	0.20
Andy Price	19321	<1	<1	0.17	0.17
Creche	19322	<1	<1	0.23	0.23
Michael Hogan	19323	<1	<1	0.22	0.22
School/Hall	19324	<1	<1	0.20	0.20
Sheedy's Shop	19325	<1	<1	0.18	0.18

Drinking Water Quality Rating: Please continue to maintain free chlorine levels at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Sincerely,

Signed: 

Lorna Moynihan

Amberley Water Solutions Ltd.