

Drinking Water Quality Certification – July 2021

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9884
Reference: 36-50
Date Sampled: 08 Jul 2021
Date Reported: 10 Jul 2021

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	27649	<1	<1	0.13	0.13
R Murphy	27650	<1	<1	0.28	0.32
Creche	-	-	-	-	-
Michael Hogan	27652	<1	<1	0.19	0.24
School/Hall	27653	<1	<1	0.05	0.05
Londis Shop	27654	<1	<1	0.11	0.11

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to maintain free chlorine at approx. 0.2 mg/L.

The Creche was closed at the time of sampling.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.