

Drinking Water Quality Certification – July 2022

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10377
Reference: 38-22/23
Date Sampled: 06 Jul 2022
Date Reported: 08 Jul 2022

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	29303	<1	<1	0.14	0.14
R Murphy	29304	<1	<1	0.40	0.42
Michael Hogan	29305	<1	<1	0.32	0.33
School	29306	<1	<1	0.04	0.04
Londis Shop	29307	<1	<1	0.14	0.15
Banner Steel	29308	<1	<1	0.16	0.16

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.