

Drinking Water Quality Certification – July 2023

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10891
Reference: 40-1
Date Sampled: 05 Jul 2023
Date Reported: 09 Jul 2023

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	31332	<1	<1	0.09	0.09
R Murphy	31333	<1	<1	0.15	0.16
Michael Hogan	31334	<1	<1	0.20	0.21
School	31335	<1	<1	0.06	0.06
Londis Shop	31336	<1	<1	0.16	0.17
Banner Steel	31337	<1	<1	0.10	0.10

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.