

Drinking Water Quality Certification – July 2025

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 11874
Reference: 43-62
Date Sampled: 09 Jul 2025
Date Reported: 15 Jul 2025

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	35885	<1	<1	0.08	0.10
R Murphy	35884	<1	<1	0.24	0.30
Michael Hogan	35883	<1	<1	0.01	0.04
School	-	-	-	-	-
Londis Shop	35882	<1	<1	0.00	0.00
Banner Steel	35886	<1	<1	0.09	0.17

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.