

19/06/2015

Mr. Adrian Donnelly,
Treasurer Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No. 7705
Ref: 26-81

Dear Adrian,

Re: Drinking Water Quality Certification – June 2015

We examined six drinking water samples taken from the indicated locations on the 12/06/2015 to determine the level of compliance with the drinking water/food regulations on coliforms and chemical parameters indicated.

Regulations:


SI 278 of 2007 and the Drinking Water Directive.
Food hygiene regulations

Sample location	Sample No.	Total coliforms No./100 mL	E. Coli No./100 mL	Residual free chlorine mg/L	Total chlorine mg/L
Pat Haren	19287	<1	<1	2.50	2.60
Andy Price	19288	<1	<1	1.50	1.50
Creche	19289	<1	<1	3.00	3.00
Michael Hogan	19290	<1	<1	0.80	0.80
School/Hall	19291	<1	<1	1.10	1.10
Sheedy's Shop	19292	<1	<1	1.60	1.60

Drinking Water Quality Rating: Free chlorine levels are very high. Please maintain free chlorine levels at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Sincerely,

Signed: 

Lorna Moynihan

Amberley Water Solutions Ltd.