

### **Drinking Water Quality Certification – June 2023**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 10845  
**Reference:** 39-184  
**Date Sampled:** 20 Jun 2023  
**Date Reported:** 24 Jun 2023

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	31242	<1	<1	0.06	0.06
R Murphy	31243	<1	<1	0.14	0.14
Michael Hogan	31244	<1	<1	0.32	0.33
School	31245	<1	<1	0.11	0.11
Londis Shop	31246	<1	<1	0.05	0.05
Banner Steel	31247	<1	<1	0.05	0.05

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.