

### **Drinking Water Quality Certification – June 2024**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 11355  
**Reference:** 41-117  
**Date Sampled:** 04 Jun 2024  
**Date Reported:** 09 Jun 2024

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	33520	<1	<1	0.20	0.20
R Murphy	33521	<1	<1	0.40	0.40
Michael Hogan	33522	<1	<1	0.53	0.53
School	-	-	-	-	-
Londis Shop	33524	<1	<1	0.13	0.13
Banner Steel	33525	<1	<1	0.11	0.11

**Comment:** The school was closed at the time of sampling. No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.