

### **Drinking Water Quality Certification – June 2025**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 11835  
**Reference:** 43-39  
**Date Sampled:** 12 Jun 2025  
**Date Reported:** 22 Jun 2025

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	35719	<1	<1	0.12	0.22
R Murphy	35720	<1	<1	0.10	0.13
Michael Hogan	35721	<1	<1	0.00	0.00
School	35722	<1	<1	0.00	0.00
Londis Shop	35723	<1	<1	0.07	0.10
Banner Steel	35724	<1	<1	0.12	0.20

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.