

25/03/2015

Mr. Adrian Donnelly,  
 Treasurer Killone GWS,  
 Imleach,  
 Barntick,  
 Ballynacally,  
 Co. Clare.

Report No. 7619  
 Ref: 26-17

Dear Adrian,

**Re: Drinking Water Quality Certification – March 2015**

We examined six drinking water samples taken from the indicated locations on the 18/03/2015 to determine the level of compliance with the drinking water/food regulations on coliforms and chemical parameters indicated.

**Regulations:**

SI 278 of 2007 and the Drinking Water Directive.  
 Food hygiene regulations


Sample location	Sample No.	Total coliforms No./100 mL	E. Coli No./100 mL	Residual free chlorine mg/L	Total chlorine mg/L
Pat Haren	18990	<1	<1	0.23	0.23
Andy Price	18991	<1	<1	0.20	0.20
Creche	18992	<1	<1	0.25	0.25
Michael Hogan	18993	<1	<1	0.23	0.23
School/Hall	18994	<1	<1	0.20	0.20
Sheedy's Shop	18995	<1	<1	0.21	0.21

**Drinking Water Quality Rating:**

Please continue to maintain free chlorine levels at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Sincerely,

Signed: 

Lorna Moynihan

Amberley Water Solutions Ltd.