

Drinking Water Quality Certification – March 2021

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9725
Reference: 35-111
Date Sampled: 09 Mar 2021
Date Reported: 13 Mar 2021

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	-	-	-	-	-
R Murphy	27059	<1	<1	0.48	0.53
Creche	27060	<1	<1	0.08	0.10
Michael Hogan	27061	<1	<1	0.45	0.50
School/Hall	27062	<1	<1	0.15	0.16
Londis Shop	27063	<1	<1	0.08	0.12

Comment: No Coliforms or *E. coli* were detected in the samples tested. Please ensure to maintain free chlorine at approx. 0.2 mg/L.

Samples were not taken from location: P. Haren due to Covid-19 Guidelines.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.