

Drinking Water Quality Certification – March 2022

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10200
Reference: 37-89
Date Sampled: 04 Mar 2022
Date Reported: 06 Mar 2022

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	28686	<1	<1	0.16	0.18
R Murphy	28687	<1	<1	0.34	0.38
Michael Hogan	28688	<1	<1	0.48	0.50
School/Hall	28689	<1	<1	0.08	0.08
Londis Shop	28690	<1	<1	0.12	0.17

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.