

Drinking Water Quality Certification – March 2023

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10728
Reference: 39-103
Date Sampled: 08 Mar 2023
Date Reported: 11 Mar 2023

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	30656	<1	<1	0.08	0.08
R Murphy	30657	<1	<1	0.52	0.53
Michael Hogan	30658	<1	<1	0.58	0.60
School	30659	<1	<1	0.06	0.06
Londis Shop	30660	<1	<1	0.19	0.19
Banner Steel	30661	<1	<1	0.04	0.04

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.