

## **Drinking Water Quality Certification – March 2024**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 11235  
**Reference:** 41-32  
**Date Sampled:** 01 Mar 2024  
**Date Reported:** 13 Mar 2024

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	32876	<1	<1	0.20	0.20
R Murphy	32877	<1	<1	0.56	0.57
Michael Hogan	32878	<1	<1	0.68	0.69
School	32879	<1	<1	0.05	0.05
Londis Shop	32880	<1	<1	0.03	0.03
Banner Steel	32881	<1	<1	0.05	0.05

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.