

Drinking Water Quality Certification – March 2025

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 11722
Reference: 42-165
Date Sampled: 06 Mar 2025
Date Reported: 09 Mar 2025

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	35205	<1	<1	0.75	0.96
R Murphy	-	-	-	-	-
Michael Hogan	35207	<1	<1	0.65	0.69
School	35210	-	-	0.27	0.27
Londis Shop	35209	<1	<1	0.60	0.64
Banner Steel	35208	<1	<1	1.48	1.58

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

No flow at Murphy's, so we were unable to sample.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.