

Drinking Water Quality Certification – May 2021

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9798
Reference: 35-144
Date Sampled: 05 May 2021
Date Reported: 09 May 2021

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	27253	<1	<1	0.12	0.14
R Murphy	27254	<1	<1	0.48	0.52
Creche	27255	<1	<1	0.10	0.13
Michael Hogan	27256	<1	<1	0.48	0.56
School/Hall	27257	<1	<1	0.05	0.05
Londis Shop	27258	<1	<1	0.13	0.16

Comment: No Coliforms or *E. coli* were detected in the samples tested. Please continue to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.