

### **Drinking Water Quality Certification – May 2022**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 10276  
**Reference:** 37-157  
**Date Sampled:** 11 May 2022  
**Date Reported:** 16 May 2022

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	29078	<1	<1	0.15	0.15
R Murphy	29079	<1	<1	0.49	0.50
Michael Hogan	29080	<1	<1	0.40	0.42
School	29081	<1	<1	0.05	0.05
Londis Shop	29082	<1	<1	0.20	0.20
Banner Steel	29083	<1	<1	0.14	0.14

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.