

### **Drinking Water Quality Certification – May 2023**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 10811  
**Reference:** 39-149  
**Date Sampled:** 05 May 2023  
**Date Reported:** 09 May 2023

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	31031	<1	<1	0.11	0.11
R Murphy	31032	<1	<1	0.52	0.53
Michael Hogan	31033	<1	<1	0.36	0.36
School	31034	<1	<1	0.10	0.10
Londis Shop	31035	<1	<1	0.19	0.19
Banner Steel	31036	<1	<1	0.06	0.06

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.