

Drinking Water Quality Certification – May 2025

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 11794
Reference: 43-16
Date Sampled: 08 May 2025
Date Reported: 10 May 2025

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	-	-	-	-	-
R Murphy	35613	<1	<1	0.47	0.64
Michael Hogan	35614	<1	<1	0.32	0.35
School	35615	<1	<1	0.10	0.16
Londis Shop	35616	<1	<1	0.00	0.00
Banner Steel	35617	<1	<1	0.20	0.35

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

Pat Haren wasn't home, so we were unable to sample.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.