

## **Drinking Water Quality Certification – November 2021**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 10049  
**Reference:** 36-168  
**Date Sampled:** 02 Nov 2021  
**Date Reported:** 07 Nov 2021

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	28205	<1	<1	0.24	0.25
R Murphy	28206	<1	<1	0.56	0.58
Creche	-	-	-	-	-
Michael Hogan	28207	<1	<1	0.55	0.57
School/Hall	28208	<1	<1	0.17	0.17
Londis Shop	28209	<1	<1	0.15	0.16

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

The Creche was closed at the time of sampling.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.