

### **Drinking Water Quality Certification – November 2023**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 11073  
**Reference:** 40-129  
**Date Sampled:** 03 Nov 2023  
**Date Reported:** 12 Nov 2023

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	32189	<1	<1	0.02	0.02
R Murphy	32190	<1	<1	0.04	0.04
Michael Hogan	32191	<1	<1	0.05	0.05
School	-	-	-	-	-
Londis Shop	32193	<1	<1	0.03	0.03
Banner Steel	32194	<1	<1	0.01	0.02

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

School was closed for mid-term.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.