

Drinking Water Quality Certification – November 2024

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 11572
Reference: 42-64
Date Sampled: 01 Nov 2024
Date Reported: 08 Nov 2024

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	34539	<1	<1	0.32	0.33
R Murphy	34540	<1	<1	0.62	0.62
Michael Hogan	34541	<1	<1	0.62	0.62
School*	-	-	-	-	-
Londis Shop	34543	<1	<1	0.42	0.42
Banner Steel	34544	<1	<1	0.40	0.40

*School was closed.

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.