

28.10.2014

Mr. Adrian Donnelly,
 Treasurer Killone GWS,
 Imleach,
 Barntick,
 Ballynacally,
 Co. Clare.

Report No. 7469
 Ref: 25-66

Dear Adrian,

Re: Drinking Water Quality Certification – October 2014

We examined six drinking water samples taken from the indicated locations on the 20/10/2014 to determine the level of compliance with the drinking water/food regulations on coliforms and chemical parameters indicated.

Regulations:

SI 278 of 2007 and the Drinking Water Directive.
 Food hygiene regulations


Sample location	Sample No.	Total coliforms No./100 mL	E. Coli No./100 mL	Residual free chlorine mg/L	Total chlorine mg/L
Pat Haren	18516	<1	<1	0.18	0.25
Andy Price	18520	<1	<1	0.23	0.29
Creche	18515	<1	<1	0.04	0.06
Michael Hogan	18519	<1	<1	0.37	0.57
School/Hall	18517	<1	<1	0.23	0.40
Sheedy's Shop	18518	<1	<1	0.27	0.36

Drinking Water Quality Rating:

Please continue to maintain free chlorine levels at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Sincerely,

Signed: 

Lorna Moynihan

Amberley Water Solutions Ltd.