

19/10/2015

Mr. Adrian Donnelly,
Treasurer Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No. 7819
Ref: 27-7

Dear Adrian,

Re: Drinking Water Quality Certification – October 2015

We examined six drinking water samples taken from the indicated locations on the 16/10/2015 to determine the level of compliance with the drinking water/food regulations on coliforms and chemical parameters indicated.

Regulations:

SI 278 of 2007 and the Drinking Water Directive.
Food hygiene regulations

Sample location	Sample No.	Total coliforms No./100 mL	E. Coli No./100 mL	Residual free chlorine mg/L	Total chlorine mg/L
Pat Haren	19676	<1	<1	0.07	0.07
Andy Price	19677	<1	<1	0.09	0.09
Creche	19678	<1	<1	0.08	0.08
Michael Hogan	19679	<1	<1	0.18	0.18
School/Hall	19680	<1	<1	0.06	0.06
Sheedy's Shop	19681	<1	<1	0.06	0.14

Drinking Water Quality Rating: Please maintain free chlorine levels at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Sincerely,

Signed:



Lorna Moynihan

Amberley Water Solutions Ltd.