

Drinking Water Quality Certification – October 2020

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9612
Reference: 35-60
Date Sampled: 09 Oct 2020
Date Reported: 11 Oct 2020

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	26809	<1	<1	0.07	0.09
R Murphy	26810	<1	<1	0.08	0.10
Creche	26811	<1	<1	0.04	0.07
Michael Hogan	26812	<1	<1	0.12	0.15
School/Hall	26813	<1	<1	0.01	0.04
Londis Shop	26814	<1	<1	0.08	0.10

Comment: No Coliforms or *E. coli* were detected in the samples tested. Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.