

Drinking Water Quality Certification – October 2024

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 11520
Reference: 42-28
Date Sampled: 07 Oct 2024
Date Reported: 19 Oct 2024

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	34267	<1	<1	0.15	0.15
R Murphy	34268	<1	<1	0.95	0.97
Michael Hogan	34269	<1	<1	0.88	0.88
School*	34270	<1	<1	0.24	0.24
Londis Shop	34271	<1	<1	0.16	0.16
Banner Steel	34272	<1	<1	0.07	0.07

*School was closed. Sample taken from kitchen in Hall.

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.