

15.09.2014

Mr. Adrian Donnelly,
Treasurer Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No. 7430
Ref: 25-16

Dear Adrian,

Re: Drinking Water Quality Certification – September 2014

We examined six drinking water samples taken from the indicated locations on the 12/09/2014 to determine the level of compliance with the drinking water/food regulations on coliforms and chemical parameters indicated.

Regulations:

SI 278 of 2007 and the Drinking Water Directive.
Food hygiene regulations

Sample location	Sample No.	Total coliforms No./100 mL	E. Coli No./100 mL	Residual free chlorine mg/L	Total chlorine mg/L
Pat Haren	18320	<1	<1	0.18	0.25
Andy Price	18319	<1	<1	0.20	0.28
Creche	18321	<1	<1	0.20	0.31
Michael Hogan	18318	<1	<1	0.15	0.24
School/Hall	18316	<1	<1	0.30	0.51
Sheedy's Shop	18317	<1	<1	0.24	0.34

Drinking Water Quality Rating:

Please maintain free chlorine levels at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Sincerely,

Signed: 

Lorna Moynihan

Amberley Water Solutions Ltd.