

26/09/2015

Mr. Adrian Donnelly,  
Treasurer Killone GWS,  
Imleach,  
Barn tick,  
Ballynacally,  
Co. Clare.

Report No. 7789  
Ref: 26-140

Dear Adrian,

**Re: Drinking Water Quality Certification – September 2015**

We examined six drinking water samples taken from the indicated locations on the 18/09/2015 to determine the level of compliance with the drinking water/food regulations on coliforms and chemical parameters indicated.

**Regulations:** SI 278 of 2007 and the Drinking Water Directive.  
Food hygiene regulations

Sample location	Sample No.	Total coliforms No./100 mL	E. Coli No./100 mL	Residual free chlorine mg/L	Total chlorine mg/L
Pat Haren	19541	<1	<1	0.13	0.13
Andy Price	19542	<1	<1	0.10	0.10
Creche	19543	<1	<1	0.10	0.10
Michael Hogan	19544	<1	<1	0.13	0.13
School/Hall	19545	<1	<1	0.07	0.07
Sheedy's Shop	19546	<1	<1	0.09	0.09

**Drinking Water Quality Rating:** Please maintain free chlorine levels at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Sincerely,

Signed: 

Lorna Moynihan

Amberley Water Solutions Ltd.