

Drinking Water Quality Certification – September 2019

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9189
Reference: 33-96/100
Date Sampled: 06 Sep 2019
Date Reported: 15 Sep 2019

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L	Total Hardness mg/L CaCO ₃
Pat Haren	25189	<1	<1	0.13	0.16	165
R Murphy	25190	<1	<1	0.22	0.24	175
Creche	25191	<1	<1	0.03	0.05	160
Michael Hogan	25192	<1	<1	0.15	0.20	160
School/Hall	25193	<1	<1	0.12	0.13	155
Sheedy's Shop	25194	73.8	<1	0.12	0.14	155

Drinking Water Quality Rating: Coliforms were detected in the sample taken from Sheedy's Shop. A re-sample was taken which confirmed the presence of Coliforms in the sample on 09/09/2019. The tap is a mixer tap and it is recommended to change to individual taps for hot and cold water. It is advised not to drink the water from this tap until issue resolved.

Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.