

Drinking Water Quality Certification – September 2023

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10970
Reference: 40-61
Date Sampled: 05 Sep 2023
Date Reported: 11 Sep 2023

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	31763	<1	<1	0.10	0.10
R Murphy	31764	<1	<1	0.24	0.24
Michael Hogan	31765	<1	<1	0.14	0.14
School	31766	<1	<1	0.10	0.10
Londis Shop	31767	<1	<1	0.16	0.16
Banner Steel	31768	<1	<1	0.12	0.12

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.