

### **Drinking Water Quality Certification – September 2024**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 11481  
**Reference:** 42-7  
**Date Sampled:** 04 Sep 2024  
**Date Reported:** 13 Sep 2024

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	34171	<1	<1	0.08	0.08
R Murphy	34172	<1	<1	0.82	0.82
Michael Hogan	34173	<1	<1	0.86	0.86
School	34174	<1	<1	0.07	0.07
Londis Shop	34175	<1	<1	0.20	0.20
Banner Steel	34176	<1	<1	0.07	0.07

**Comment:** No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.