

---

## **Drinking Water Quality Certification – September 2019**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 9209  
**Reference:** 33-101  
**Date Sampled:** 18 Sep 2019  
**Date Reported:** 29 Sep 2019

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Londis Shop	25209	<1	<1	0.13	0.16

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

Re-sample taken post tap replacement.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.